

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106


1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Quest Flooring Pty Ltd  
43-55 Mark Anthony Drive  
Dandenong South VIC 3175

**Test Number :** 24-002215  
**Issue Date :** 21/06/2024  
**Print Date :** 21/06/2024

**Sample Description** Clients Ref : "Spring Cove"  
Twist pile carpet  
Colour : Beige  
End Use : Flooring  
Nominal Composition : Solution Dyed Soft Polyester  
Nominal Mass per Unit Area/Density : 1360g/m2  
Nominal Thickness : 13mm



324187

71275

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Quest Flooring Pty Ltd  
43-55 Mark Anthony Drive  
Dandenong South VIC 3175

**Test Number :** 24-002215  
**Issue Date :** 21/06/2024  
**Print Date :** 21/06/2024

### AS 4586-2013 Appendix A

### Slip Resistance Classification of New Pedestrian Surface Materials Dry Pendulum Test Method

Date of Testing 20-06-2024  
Operator AWTA Test Operator 4  
Test Temperature 21 °C  
Sample tested as received, no underlay  
Pile Direction Length  
Fixed/Unfixed Unfixed  
Slider No 96 Batch No 23

Length	1	2	3	4	5	SRV
British Pendulum Number	66	60	66	67	65	65

Classification (Surface tested dry) P5

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 11/10/2023  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

324187

71275

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Fiona McDonald

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR